



Bransonic Bath

Instruction Manual



Manual Change Information

At Branson, we strive to maintain our position as the leader in ultrasonics plastics joining, metal welding, cleaning and related technologies by continually improving our circuits and components in our equipment. These improvements are incorporated as soon as they are developed and thoroughly tested.

Information concerning any improvements will be added to the appropriate technical documentation at its next revision and printing. Therefore, when requesting service assistance for specific units, note the Revision information found on the cover of this document, and refer to the printing date which appears at the bottom of this page.

Copyright and Trademark Notice

Copyright © 2017 Branson Ultrasonics Corporation. All rights reserved. Contents of this publication may not be reproduced in any form without the written permission of Branson Ultrasonics Corporation.

Mylar is a registered trademark of DuPont Teijin Films.

Loctite is a registered trademark of Loctite Corporation.

WD-40 is a registered trademark of WD-40 Company.

Windows 7, Windows Vista, and Windows XP are registered trademarks of Microsoft Corporation

Other trademarks and service marks mentioned herein are held by their respective owners.



Foreword

Congratulations on your choice of a Branson Ultrasonics Corporation system!

The Branson Ultrasonic Bath system is process equipment for the cleaning of parts using ultrasonic energy. It is the newest generation of product using this sophisticated technology for a variety of customer applications. This Instruction Manual is part of the documentation set for this system, and should be kept with the equipment.

Thank you for choosing Branson!

Introduction

This manual is arranged into several structured chapters which will help you find the information you may need to know to safely handle, install, set up, program, operate, and/or maintain this product. Please refer to the <u>Table of Contents</u> and/or the <u>Index</u> of this manual to find the information you may be looking for. In the event you require additional assistance or information, please contact our Product Support department (see <u>1.3 Limited Warranty</u> for information on how to contact them) or your local Branson representative.

Table of Contents

Chapter '	I:Safety and Support
1.1	Safety Requirements and Warnings
1.2	Safety Precautions
1.3	Limited Warranty 5
Chapter 2	2:Introduction
2.1	How Ultrasonics Works 8
2.2	Ultrasonic Baths
Chapter 3	3:Delivery and Handling
3.1	Unpacking Your Unit
Chapter 4	1:Technical Specifications
4.1	Model Name Definition
4.2	Equipment Specifications
4.3	Temperature
4.4	Cleaning Solutions
4.5	Solution Effect on Metals
Chapter !	5:Installation and Setup
5.1	Installing Your Unit
Chapter	5:Operation
6.1	Operating Your Ultrasonic Bath
6.2	M Series
6.3	MH Series
6.4	CPX Series
6.5	CPXH Series
6.6	Cleaning Methods
Chapter	7:Maintenance
7.1	Optimizing Your Ultrasonic Bath
7.2	Troubleshooting
7.3	Glass Slide Test
7.4	Service Centers
7.5	Information for Users on Disposal of Equipment

List of Figures

Chapter 1	:Safety and Support
Chapter 2	2:Introduction
Chapter 3	B:Delivery and Handling
Chapter 4	:Technical Specifications
Chapter 5	:Installation and Setup
	:Operation
Figure 6.1	M Series Controls
	MH Series Controls
	CPX Series Controls
	CPXH Series Controls
Figure 6.5	Draining of Units 1800 and 280055
Figure 6.6	Direct Cleaning Method
Figure 6.7	Indirect Cleaning Method
Figure 6.8	Non Cleaning Application
Chapter 7	':Maintenance

List of Tables

Chapter 1	:Safety and Support	
Chapter 2 Table 2.1	2:Introduction Ultrasonic Baths Available	9
Chapter 3	:Delivery and Handling	
Chapter 4 Table 4.1 Table 4.2 Table 4.3 Table 4.4 Table 4.5 Table 4.6 Table 4.7 Table 4.8 Table 4.9 Table 4.10 Table 4.11	Model Name Definition	15 16 17 18 19 20 21 22 23
Chapter 5	:Installation and Setup	
•	o:Operation	
Table 6.1 Table 6.2 Table 6.3 Table 6.4 Table 6.5 Table 6.6 Table 6.7 Table 6.8 Table 6.9 Table 6.10 Table 6.11 Table 6.12	Before you Begin M Series Explanation of Controls For initial cleaning solution degassing. Treating Samples Before you Begin MH Series Explanation of Controls For initial cleaning solution degassing. Treating Samples Before you begin CPX Series explanation of controls CPX Series LCD description. Degassing your CPX Series unit	32 33 34 35 36 37 38 40
Table 6.13 Table 6.14 Table 6.15 Table 6.16 Table 6.17 Table 6.18 Table 6.19 Table 6.20	Degassing your CPX Series unit. Treating Samples Before you begin. CPXH Series explanation of controls. LCD Description for CPXH Series. Degassing Ultrasonic Operating Modes Treating samples in Timed Sonics Mode Treating Samples in Constant Sonics Mode.	42 43 44 49 50 51
Table 6.21 Table 6.22 Table 6.23 Table 6.24 Table 6.25	Treating Samples in Auto Mode	54 55

Chapter	7:Maintenance	
Table 7.1	Tanks	64
Table 7.2	Troubleshooting	65
Table 7.3	Authorized Service Centers (North America)	68
Table 7.4	Technical Support (North America)	68
Table 7.5	Authorized Service Center/Technical Support (Europe)	69
Table 7.6	Authorized Service Center/Technical Support (Asia)	69



Chapter 1: Safety and Support

1.1	Safety Requirements and Warnings	2
	Safety Precautions	
1.3	Limited Warranty	Ę

1.1 Safety Requirements and Warnings

This chapter contains an explanation of the different Safety Notice symbols and icons found both in this manual and on the product itself and provides additional safety information for ultrasonic welding. This chapter also describes how to contact Branson for assistance.

1.2 Safety Precautions

Before using your Ultrasonic Bath, please read and thoroughly understand these safety precautions. Failure to follow them may result in serious personal injury or property damage.

1.2.1 To avoid electrical shock:

- · Do unplug from power source before filling or emptying the tank
- · Do plug the unit into an appropriate grounded power socket
- Do connect the unit to a power supply using a properly sized overcurrent protection device. See label on the back of unit for information on current rating
- Do keep the control panel and the area around the unit clean and dry—wipe up solution which spills over the tank brim. Water and high voltage can cause electrical shock
- · Do not operate the unit without proper grounding
- · Do not remove the grounding prong on the line cord plug
- Do not disassemble your unit—high voltage inside the unit is dangerous
- · Do not immerse the unit in water

1.2.2 To prevent personal and/or property damage:

- · Do use water-based solutions
- Do not ever use alcohol, gasoline or flammable solutions. Doing so could cause a fire or explosion and will void your warranty. Use only water-based solutions
- · Do not ever use mineral acids. These could damage the tank
- · Do not touch the stainless steel tank or cleaning solution—they may be hot
- Do not allow fluid temperature to exceed 70° C (158° F)
- Do not place your fingers or hands into the tank while the unit is operating. Doing so may cause discomfort and possible skin irritation. Avoid contact with solutions and provide adequate ventilation
- · Do not use solutions containing chlorine bleach

1.2.3 To prevent damage to the unit:

- · Do change your solution regularly
- · Do not cover vents on the cover
- Do not operate the unit dry
- Do not place parts or containers directly on the bottom of the tank; use a tray or wire to suspend items. Failure to comply may cause transducer damage and will void your warranty
- Do not allow the solution to drop more than 3/8 inch (1 cm) below the operating level line with heat or ultrasonics on. Failure to comply may cause transducer and/or heater damage and will void your warranty
- · Turn off AC and heater switch before plugging/unplugging the line cord

1.2.4 Sound level and energy savings

- Do not operate the unit without a cover when possible
- The sound pressure released by the unit depends on the size of the bath and the application, but is less than 80 dBA when used with a cover
- To reduce the sound pressure it is recommended to use a cover while ultrasonics are activated and to switch the ultrasonics on with the bath loaded when possible

1.2.5 Insulation resistance test

Branson has taken all applicable measures to assure that manufactured units comply with insulation resistance requirements, as outlined by IEC 61010-1:2010 (Third edition). As

per the Portable Appliance Testing (PAT) requirements, testing should be carried out by the user.

Before doing the insulation testing, however, please read the following pertinent information:

All of Branson's 220 V "C" and 230 V "E" units are equipped with Metal Oxide Varistors (MOVs) as the primary components to absorb overvoltages in the power line. MOVs disperse the over-voltage to the ground line and thus away from the equipment. Per their mode of operation, these MOVs will cause the insulation resistance test to fail when it is carried out at 500 V DC. As such, Branson recommends performing the test at a reduced voltage (250 V DC), as allowed by the Code of Practice for In-service Inspection and Testing of Electrical Equipment published by the IET (The Institution of Engineering and Technology), as this will prevent the MOVs from triggering and failing the test.

1.3 Limited Warranty

Subject to the limitations outlined below, Branson warrants that the Ultrasonic Baths will be free from defects in material and workmanship under normal use and regular service and maintenance for a period of **twenty four (24) months from the date of shipment**. Branson does not warrant that the operation of the software shall be uninterrupted or error free. THIS IS THE SOLE AND EXCLUSIVE WARRANTY GIVEN WITH RESPECT TO THE ULTRASONIC BATHS AND IS IN LIEU OF AND EXCLUDES ALL OTHER WARRANTIES, EXPRESS OR IMPLIED, ARISING BY OPERATION OF LAW OR OTHERWISE, INCLUDING WITHOUT LIMITATION, MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE WHETHER OR NOT THE PURPOSE OR USE HAS BEEN DISCLOSED TO BRANSON.

This warranty does not extend to any losses or damages due to misuse, accident, abuse, neglect, normal wear and tear, negligence (other than Branson's), unauthorized modification or alteration, use beyond rated capacity, unsuitable power sources or environmental conditions, improper installation, repair, handling, maintenance or application or any other cause not the fault of Branson. If within thirty (30) days after discovery of any warranty defects within the warranty period, the Customer notifies Branson thereof in writing, Branson shall, at its option and as the Customer's exclusive remedy, repair, correct or replace, or refund the purchase price for, that portion of the product found by Branson to be defective. Failure by the Customer to give such written notice within the applicable time period shall be deemed an absolute and unconditional waiver of the Customer's claim for such defects. The Customer must return the product to one of the Branson service centers, whose addresses are provided on 7.4 Service Centers of this manual. The Customer will be responsible for freight sending the unit to the service center. The service center will send the unit back to the Customer with freight prepaid. Branson's liability, whether based on warranty, negligence, tort or strict liability, or other cause, arising out of and/or incidental to sale, use or operation of the transducer elements, or any part thereof, shall not in any case exceed the cost of repair or replacement of the defective equipment, and such repair or replacement shall be the exclusive remedy of the purchaser, and in no case shall Branson be responsible for any and/or all consequential punitive or incidental damages including without limitation, and/ or any consequential damages arising out of commercial losses.

WARNING	General Warning	
\wedge	 Do not place parts or containers directly on the bottom of the tank; use a tray or wire to suspend items. Direct placement can cause the units to fail Do not allow the solution to drop more than 3/8 inch (1 cm) below the operating level line 	
•	 Do not ever use alcohol, gasoline or flammable solutions. Doing so could cause a fire or explosion. Use only water-based solutions Do not use mineral acids. These could damage the tank 	

First time cleaning - First experiment with one piece, then proceed with the remainder.



CAUTION	General Warning
	Never clean novelty or inexpensive jewelry in the ultrasonic bath. The combination of heat and vibration may loosen a cement-held setting. Never clean gemstones such as emerald, amethyst, pearl, opal, coral, turquoise, peridot or lapis lazuli in the ultrasonic bath.

Solution level - Be sure to maintain solution level within 1/2 inch (1.3 cm) of the tank's "operating level" line. Surface activity can vary with liquid level.

Load size - It is faster and more efficient to run several small loads rather than a few big loads.

Placing items - Never allow items to sit on the bottom of the tank. Always place them in a tray or beaker or suspend in the solution.

Rinsing items - After cleaning, use a clean water bath to rinse away chemicals adhering to items.

Lubricating items - When necessary, re-lubricate items immediately after cleaning.

Drying items - Air drying at room temperature works for some items. Place parts requiring faster drying time under hot air blowers or in ovens.

Please call your local distributor if you have application questions.




Chapter 2: Introduction

2.1	How Ultrasonics Works
2.2	Ultrasonic Baths


2.1 How Ultrasonics Works

Ultrasonic sound is sound transmitted at frequencies generally beyond the range of human hearing. In your ultrasonic bath, ultrasonic sound (sonics) can be used for cleaning materials and parts, and for dissolving, homogenizing and degassing liquids. This is how it works:


 As the sound waves from the transducer radiate through the solution in the tank, they cause alternating high and low pressures in the solution



• During the low pressure stage, millions of microscopic bubbles form and grow. This process is called CAVITATION, meaning "formation of cavities"



- During the high pressure stage, the bubbles collapse, or "implode" releasing enormous amounts of energy
- For ultrasonic cleaning applications, these implosions act like an army of tiny scrub brushes. They work in all directions, attacking every surface and invading all recesses and openings



 This same energy can be used for other applications, such as liquid dissolving, homogenizations, and degassing

2.2 Ultrasonic Baths

This line of ultrasonic baths include five sizes:

Table 2.1 Ultrasonic Baths Available

Model Number	Tank Capacity
1800	1/2 gal. (1.91 l)
2800	3/4 gal. (2.81 l)
3800	1-1/2 gal. (5.71 l)
5800	2-1/2 gal. (9.51 l)
8800	5-1/2 gal. (20.81 l)

Each model is constructed using durable industrial style 40 kHz transducers. These provide increased ultrasonic power along with built in sweep frequency to ensure uniform ultrasonic activity throughout the bath. Models 1800 and 2800 have a molded dip in the left side of their rims to facilitate emptying of solution from the tank. Models 3800, 5800 and 8800 have built in drains and are supplied with tank drain kits. Each model can be purchased in four different configurations:

- With a Mechanical Timer (M);
- · With a Mechanical Timer plus Heat (MH);
- With Digital Control and Timer (CPX);
- With Digital Control, plus Heat and Timer (CPXH).



When you first fill your unit, or refill it with fresh solution, use warm water for the solution. Turn on the heater (if available), turn on the ultrasonics (press the Sonics key or rotate the Timer), add the cover and the solution will heat quickly to temperature.

2.2.1 Accessories For Your Unit

As parts cannot be placed on the tank bottom, accessories include beaker positioning covers, solid and perforated insert trays, mesh baskets, beakers, and support racks.

NOTICE	
f	Tank covers are included with every unit.

Chapter 3: Delivery and Handling

3.1	Unpacking Your Unit	
-----	---------------------	--

3.1 Unpacking Your Unit

Please check your unit and its carton carefully for any external or internal damage. If you find damage, contact your shipping carrier immediately, before contacting your distributor. Please retain your packaging for future use.



Chapter 4: Technical Specifications

4.1	Model Name Definition
4.2	Equipment Specifications
4.3	Temperature
4.4	Cleaning Solutions
4.5	Solution Effect on Metals

4.1 Model Name Definition

The name of the models determine the specifications of each unit. For example the CPX1800H-E:




Table 4.1 Model Name Definition

Item	Stands For	Availability			
1	Model	CPX: Digital			
ı	iviodei	M: Mechanical			
		1800: 1/2 gal (1.91 l)			
		2800: 3/4 gal (2.81 l)			
2	Tank Capacity	3800: 1-1/2 gal (5.71 l)			
		5800 : 2-1/2 gal (9.51 l)			
		8800: 5-1/2 gal (20.81 l)			
3	Heater	Blank: No heater			
3	пеатег	H: Heater			
		Blank: North America (120 VAC)			
4	Pogion/voltago	E: Europe (230 VAC)			
4	Region/voltage	J: Japan (100 VAC)			
		C: China (220 VAC)			

- · All models have a frequency of 40 kHz
- In CPXH models, the temperature readout accuracy is ± 3° C (± 5.4° F)
- Models available for 120 V \pm 10%, 50/60 Hz and 220 V \pm 10%, 50/60 Hz operation
- · All 120 V units have CSA/UL or equivalent approval and comply with FCC regulations
- · All 220-230 V units meet CE standards
- All units have a ground leakage current less than .50 ma
- Operating ambient temperature is from 5° C to 40° C (41° F to 104° F)

4.2 **Equipment Specifications**

 Table 4.2
 Equipment Specifications for North America Models

Model Name	Tank Capacity	Tank Size (Inches)	Overall Size (inches)	Weight	Max Sonics Power	Heater Power	Max. Draw Power Req.
M1800					70	0	90
M1800H	1/2 gal.	L: 9.9 W: 5.5	L: 9.9 W: 12	9 lb	70	60	150
CPX1800H	(1.91 l)	W. 5.5 H: 4	H: 11.9	(4 kg)	70	60	150
CPX1800		11. 1	11. 11.7		70	0	90
M2800			1 10 0		110	0	130
M2800H	3/4 gal	L: 9.5 W: 5.5	L: 13.3 W: 12	10 lb	110	90	250
CPX2800H	(2.81 l)	W: 5.5 H: 4	W: 12 H: 11.9	(4.5 kg)	110	90	250
CPX2800		11. 4	11. 11.7		110	0	250
M3800			. 45 /		110	0	130
M3800H	1-1/2 gal	L: 11.5 W: 6	L: 15.6 W: 12.5	14 lb	110	180	350
CPX3800H	(5.71 l)	vv. 6 H:6	W. 12.5 H: 14.8	(6.4 kg)	110	180	350
CPX3800		11.0	11. 14.0		110	0	130
M5800			. 45 /		160	0	180
M5800H	2-1/2 gal	L: 11.5 W: 9.5	L: 15.6 W: 15.8	16 lb	160	280	490
CPX5800H	(9.51 l)	W. 9.5 H: 6	H: 14.9	(7.3 kg)	160	280	490
CPX5800		11. 0	11. 11.7		160	0	180
M8800					280	0	320
M8800H	5-1/2 gal	L: 19.5	L: 23.5	28 lb	280	560	930
CPX8800H	(20.81 I)	W: 11.5 H: 15.4	W: 18.3 H: 15.4	(12.7 kg)	280	560	930
CPX8800			11. 13.4		280	0	320

 Table 4.3
 Equipment Specifications for Europe Models

Model Name	Tank Capacity	Tank Size (mm)	Overall Size (mm)	Weight	Max Sonics Power	Heater Power	Max. Draw Power Req.
M1800-E		1 150	1 054		70	О	90
M1800H-E	1.91	L: 150 W: 140	L: 251 W: 305	5.4 kg	70	60	150
CPX1800H-E	(1/2 gal)	H: 100	H: 302	(12 lb)	70	60	150
CPX1800-E		1 100	11. 002		70	0	90
M2800-E					110	0	130
M2800H-E	2.81 I	L: 240	L: 338 W: 305	6.8 kg	110	110	250
CPX2800H-E	(3/4 gal)	W: 140 H: 100	W: 305 H: 302	(15 lb)	110	110	250
CPX2800-E					110	0	250
M3800-E		L: 290 W: 150 H: 150	L: 396 W: 318 H: 302	8.2 kg (18 lb)	110	0	130
M3800H-E	5.71 I				110	215	350
CPX3800H-E	(1-1/2 gal)				110	215	350
CPX3800-E					110	0	350
M5800-E					160	0	180
M5800H-E	9.51 I	L: 290 W: 240	L: 396 W: 401	9.5 kg	160	300	490
CPX5800H-E	(2-1/2 gal)	W. 240 H: 150	H: 378	(21 lb)	160	300	490
CPX5800-E		11. 130	11. 370		160	0	180
M8800-E					280	0	320
M8800H-E	20.81 I	L: 495	L: 597	16.3 kg	280	600	930
CPX8800H-E	(5-1/2 gal)	W: 290 H: 150	W: 465 H: 391	(36 lb)	280	600	930
СРХ8800-Е		11. 130	11. 371		280	0	320

 Table 4.4
 Equipment Specifications for Japan Models

Model Name	Tank Capacity	Tank Size (inches)	Overall Size (inches)	Weight	Max Sonics Power	Heater Power	Max. Draw Power Req.
M1800-J		1 150	. 054		70	0	90
M1800H-J	1.91	L: 150 W: 140	L: 251 W: 305	4 kg	70	45	135
CPX1800H-J	(1/2 gal)	H: 100	W. 303 H: 302	(9 lb)	70	45	140
CPX1800-J		11. 100	11. 002		70	0	90
M2800-J					110	0	130
M2800H-J	2.81 I	L: 240	L: 338	4.5 kg	110	65	205
CPX2800H-J	(3/4 gal)	W: 140 W: 305 H: 100 H: 302	(10 lb)	110	65	205	
CPX2800-J			11. 302		10	0	130
M3800-J					110	0	130
M3800H-J	5.71 I	L: 290	L: 396	6.4 kg	110	130	275
CPX3800H-J	(1-1/2 gal)	W: 150 H: 150	W: 318 H: 376	(14 lb)	110	130	280
CPX3800-J					110	0	130
M5800-J					160	0	180
M5800H-J	9.5 I	L: 290 W: 240	L: 396 W: 401	7.3 kg	160	200	405
CPX5800H-J	(2-1/2 gal)	W. 240 H: 150	H: 378	(16 lb)	160	200	410
CPX5800-J		П. 150	11. 370		160	0	180
M8800-J					280	0	320
M8800H-J	20.81 I	L: 495 W: 290	L: 597	12.7 kg	280	400	755
CPX8800H-J	(5-1/2 gal)	W: 290 H: 150	W: 465 H: 391	(28 lb)	280	400	760
CPX8800-J		11. 130	11. 371		280	0	320

 Table 4.5
 Equipment Specifications for China Models

Model Name	Tank Capacity	Tank Size (inches)	Overall Size (inches)	Weight	Max Sonics Power	Heater Power	Max. Draw Power Req.
M1800-C		1 150	1 254		70	О	90
M1800H-C	1.91 I	L: 150 W: 140	L: 251 W: 305	5.4 kg	70	55	145
CPX1800H-C	(1/2 gal)	H: 100	H: 302	(12 lb)	70	55	145
CPX1800-C		1 100	111 002		70	0	90
M2800-C					110	0	130
M2800H-C	2.81 I	L: 240 W: 140	L: 338 W: 305	6.8 kg	110	105	250
CPX2800H-C	(3/4 gal)	H: 100	W: 305 H: 302	(15 lb)	110	105	250
CPX2800-C		11. 100			110	0	130
M3800-C					110	0	130
M3800H-C	5.71 I	L: 290 W: 150	L: 396 W: 318	8.2 kg	110	205	350
CPX3800H-C	(1-1/2 gal)	W: 150 H: 150	W: 318 H: 376	(18 lb)	110	205	350
CPX3800-C					110	0	130
M5800-C					160	0	180
M5800H-C	9.5 I	L: 290 W: 240	L: 396 W: 401	9.5 kg	160	285	490
CPX5800H-C	(2-1/2 gal) W: 240 H: 150		W. 401 H: 378	(21 lb)	160	285	490
CPX5800-C		11. 130	п. 150 п. 376		160	0	180
M8800-C					280	0	320
M8800H-C	20.81 I	L: 495 W: 290	L: 597	16.3 kg	280	560	930
CPX8800H-C	(5-1/2 gal)	W: 290 H: 150	W: 465 H: 391	(36 lb)	280	560	930
CPX8800-C		11. 100	11. 371		280	0	320

 Table 4.6
 Fuse Table for North America and Japan Models

Model Name	Fuse 1	Fuse 2	Fuse 3
M1800 / M1800-J			
M1800H / M1800H-J	250 V, 2A		
CPX1800H / CPX1800H-J			
CPX1800 / CPX1800-J	250 V, 1.6A		
M2800 / M2800-J			
M2800H / M2800H-J	250 V, 2.5A	250 V, 1.6A	
CPX2800H / CPX2800H-J		250 V, 1.0A	
CPX2800 / CPX2800-J	250 V, 1.6A		
M3800 / M3800-J			
M3800H / M3800H-J	250 V, 2.5A		250 V, 1A
CPX3800H / CPX3800H-J			230 V, 1A
CPX3800 / CPX3800-J	250 V, 1.6A		
M5800 / M5800-J			
M5800H / M5800H-J	250 V, 5A	250 V, 2A	
CPX5800H / CPX5800H-J			
CPX5800 / CPX5800-J	250 V, 2.5A	250 V, 2.5A	
M8800 / M8800-J			
M8800H / M8800H-J	250 V, 10A	250 V, 3.15A	
CPX8800H / CPX8800H-J		250 V, 3.13A	
CPX8800 / CPX8800-J	250 V, 5A		

Table 4.7 Fuse Table for Europe and China Models

Model Name	Fuse 1	Fuse 2	Fuse 3
M1800-E / M1800-C			
M1800H-E / M1800H-C	250 V, 1.6A		
CPX1800H-E / CPX1800H-C	250 V, 1.0A		
CPX1800-E / CPX1800-C			
M2800-E / M2800-C			
M2800-E / M2800H-C	250 V, 2.5A	250 V, 1.6A	250 V, 1A
CPX2800H-E / CPX2800H-C		250 V, 1.0A	
CPX2800-E / CPX2800-C	250 V, 1.6A		
M3800-E / M3800-C			
M3800H-E / M3800H-C	250 V, 2.5A		
CPX3800H / CPX3800H-C			
CPX3800-E / CPX3800-C	250 V, 1.6A		
M5800-E / M5800-C			
M5800H-E / M5800H-C	250 V, 5A	250 V, 2A	
CPX5800H-E / CPX5800H-C			
CPX5800-E / CPX5800-C	250 V, 1.6A	250 V, 1.6A	
M8800-E / M8800-C			
M8800H-E / M8800H-C	250 V, 5A	250 V, 2A	
CPX8800H-E / CPX8800H-C		250 V, ZA	
CPX8800-E / CPX8800-C	250 V, 2.5A		

4.3 Temperature

Table 4.8Temperature

Item	
Heater	The heater may cause some discoloration of the tank. This is normal and will not affect the performance of the unit.
Solution	The fastest method to heat your ultrasonic bath is to fill with warm solution, use heat, ultrasonics (which also adds heat), and a cover.
Over Temperature Protection (CPXH only)	If Max Temperature of 75° C is reached, Ultrasonics will pause for a period of time until the temperature in the bath falls back down to 69° C (the max set point). Once the temperature falls back down to 69° C, Ultrasonics will resume. This will apply for both continuous/infinity mode, as well as timed mode. In timed mode, the timer will pause while Ultrasonics is off, and will resume once Ultrasonics resumes.

4.4 Cleaning Solutions

CAUTION	General Warning
	Do not use alcohol, gasoline, bleach, mineral acids, solutions with a flash point, semi-aqueous or combustible liquids in ultrasonic tanks, or you will void the warranty. Only use non-flammable solutions and water-based solutions.

4.4.1 Solution Types

Water-based solutions can be either slightly acidic or alkaline. They include detergents, soaps and industrial cleaners designed to remove specific soils.

Acidic water-based solutions: remove rust, tarnish or scale. They range from mild solutions that remove tarnish, to concentrated, inhibited acidic solutions that remove investment plaster, milk-stone, zinc oxide and rust from steel and cast iron as well as smut and heat-treat scale from hardened steel.

Alkaline water-based solutions: include carbonates, silicates and caustics. These cause emulsifying action, which keeps soil from redepositing on the cleaned surface, and improves cleaning action in hard water.

 Table 4.9
 Alkaline Solution Strength and Uses

Alkaline Strength	Removes
Mild	Light oils and greases, cutting oils and coolant compounds.
Mild to Strong	Heavy grease and oils, waxes, vegetable oils, inks, wax or fat- base buffing and polishing compounds, milk residues and carbohydrates.
Heavy-duty	Mill scale, heat-treat scale, corrosion or oxides.

Change the cleaning solution periodically. Cleaning solutions can become contaminated with suspended soil particles which coat the tank bottom. This coating dampens the ultrasonic action and reduces cleaning efficiency. Certain solutions will cavitate better than others. Contact your local distributor for further information.

Heat and cavitation increase the chemical activity of cleaning solutions. Some materials may be damaged by this stronger chemical action. When in doubt, test run samples of items to be cleaned.

Caustic solutions: used to remove rust from steels, metal alloy corrosion and a variety of tenacious soils.

4.4.2 Solution Amounts

Solution amounts may vary. The amount you use depends on the detergent and the type of soil to be removed. Follow instructions on the solution container and refer to the table below for the effects of solutions on metals.



4.4.3 Chemicals Harmful to Your Tank

The following chemicals will harm your ultrasonic tank and the action of ultrasonics and higher operating temperatures will increase their chemical activity. Do not use these or similar chemicals directly or in dilution in your ultrasonic tank or you will void your warranty.

Table 4.10 Chemicals Harmful to Your Tank

Harmful Chemicals							
Acetophenone	Chloracetic Acid	Hydrocyanic Acid					
Aluminum Chloride	Chloric Acid	Hydrofluoric Acid					
Aluminum Flouride	Chlorine, Anhydrous	Hydroflousilicic Acid					
Aluminum Sulphate	Chromic Acid	Iodoform					
Ammonium Bifluoride	Copper Chloride	Mercuric Chloride					
Ammonium Chloride	Copper Fluoborate	Muriatic Acid					
Ammonium Hydroxide	Ethyl Chloride	Phosphoric (crude)					
Amyl Chloride	Ferric Chloride	Sodium Hypochlorite					
Antimony Trichloride	Ferrous Chloride	Potassium Chloride					
Aqua Regia	Ferris Sulfate	Stannic Chloride					
Bromine	Fluoboric Acid	Stannous Chloride					
Calcium Bisulfate	Fluorine	Sulfur Chloride					
Calcium Bisulfite	Hydrobromic Acid	Sulfuric Acid					
Calcium Hypochloride	Hydrochloric Acid	Zinc Chloride					

4.5 Solution Effect on Metals

Table 4.11 Solution Effects on Metals

Cleaning Agent	Steel	Brass	Aluminum	Magnesium	Zinc	S. Steel Copper	Tin
Optical (1)	none	none	none	none**	none**	none	none**
Jewelry (1)	none	none	none	none	none	none	none
Buffing (1) Compound	none	slight stain	none	none	attacks	none	none
Oxide (2) remover	slight etch	none	slight attack	attacks	attacks	none	none
Electronic cleaner (1)	none	none	slight attack	none	none	none	none
General (1) purpose	none	none	slight attack	none	none	none	none
Industrial strength (1)	none	none	slight attack	none	none	none	none
Metal (1) cleaner 1	none	none	none	none	none	none	none
Metal (1) cleaner 2	none	none	slight attack	none	none	none	none
Metal (1) cleaner 3	none	none	none	none	none	none	none
Liquid rust (3) stripper	none	none	attacks***	attacks***	attacks	none	slight attack
GP (1) Powder	none	none	none	none	none	none	none

 $^{^{\}star}$ Contact distributor for cleaning agent availability outside the US.

^{(1) =} Alkaline; (2) = Acidic; and (3) = Caustic.

WARNING	General Warning
	*** Free hydrogen may be released if solution comes in contact with reactive metals.

^{**} No effect if solution temperature is less than 60° C (140° F).

Chapter 5: Installation and Setup

5.1	Installing Your Unit	28
-----	----------------------	----

5.1 Installing Your Unit

Check the plate on the back of the unit for correct power requirements. Position your unit within easy reach of a standard grounded electrical outlet. Do not place the unit on a circuit which could become overloaded. If your unit does not operate correctly, first refer to 7.2 Troubleshooting for possible causes, or contact an authorized service center listed at the end of this manual for additional information.



Chapter 6: Operation

6.1	Operating Your Ultrasonic Bath	3C
6.2	M Series	31
6.3	MH Series	34
6.4	CPX Series 3	37
6.5	CPXH Series	12
6.6	Cleaning Methods	57

6.1 Operating Your Ultrasonic Bath

If this is the first time you are using the ultrasonic bath, please read this whole section before operating your unit.

6.2 M Series

CAUTION	General Warning
\wedge	 Do not place parts or containers directly on the bottom of the tanks; use a tray or wire to suspend items. Direct placement can cause the units to fail Do not allow the solution to drop more than 3/8 inch (1 cm) below the operating level line with ultrasonics on
	Do not ever use alcohol, gasoline or flammable solutions. Doing so could cause a fire or explosion. Use only water-based solutions
	Do not ever use mineral acids. These could damage the tank Failure to comply with these cautions will void your warranty.

Table 6.1Before you Begin

Step	Action	
1	Select your cleaning solution (refer to 4.5 Solution Effect on Metals).	
2	Allowing for the volume of the parts you will be cleaning and leaving room for cleaning solution, fill the tank with warm tap water to the operating level line.	
3	Add cleaning solution to the tank water.	
4	Plug the unit into a grounded outlet.	
5	For maximum efficiency, refer to 7.1 Optimizing Your Ultrasonic Bath", before proceeding.	

NOTICE	
1	If this is the first time you are running the unit, or if you have changed cleaning solution, you must degas the solution. If not, skip to 6.2.3 Cleaning Items (Treating Samples)."

6.2.1 M Series Explanation of Controls

Figure 6.1 M Series Controls



Table 6.2 M Series Explanation of Controls

Control	Function
	This switch is located on the back of the unit, next to the power cord receptacle.
	Press the on side to power on the unit
Main Power Switch	Press the off side to power off the unit
	When operating the unit, normally leave the Main Power switch in the on position, and use the Timer Knob to activate ultrasonics.
	Activates ultrasonics and sets time.
	Turn clockwise for timed operation (0–60 minutes)
Timer Knob	Turn counterclockwise to the HOLD position for continuous operation
	Turn to the zero position to turn unit Off

6.2.2 Degassing

For initial cleaning solution degassing.

 Table 6.3
 For initial cleaning solution degassing.

Step	Action
1	Turn Main Power switch on.
2	Turn the Timer Knob clockwise to 5–10 and let the unit run to allow the solution to "degas". NOTICE Refer to 6.5.11 Solution for information on degassing.

6.2.3 Cleaning Items (Treating Samples)

NOTICE	
1	To stop ultrasonics at any time, turn the Timer Knob to the zero position.

Table 6.4Treating Samples

Step	Action
1	Turn Main Power switch on.
2	Turn the Timer Knob clockwise to set the amount of time (0 - 60 minutes) you wish the items to be cleaned. Turn the Timer Knob counterclockwise to the Hold position for continuous operation.
3	Place the items into a basket, perforated tray, or beakers in a positioning cover.
4	If using beakers or a solid tray, add cleaning solution to beakers or tray to cover the items.
5	Slowly lower the tray or beakers into the tank. Do not allow items to contact the tank bottom.
6	When items are clean, slowly remove them from the tank.
7	Rinse the clean items with clean water and dry them, if necessary.

6.3 MH Series

CAUTION	General Warning
A	Do not place parts or containers directly on the bottom of the tanks; use a tray or wire to suspend items. Direct placement can cause the units to fail
	Do not allow the solution to drop more than 3/8 inch (1 cm) below the operating level line with heat or ultrasonics on
	Do not ever use alcohol, gasoline or flammable solutions. Doing so could cause a fire or explosion. Use only water-based solutions
	Do not ever use mineral acids. These could damage the tank
	Failure to comply with these cautions will void your warranty.

Table 6.5Before you Begin

Step	Action
1	Select your cleaning solution (refer to 4.5 Solution Effect on Metals).
2	Allowing for the volume of the parts you will be cleaning and leaving room for cleaning solution, fill the tank with warm tap water to the operating level line.
3	Add cleaning solution to the tank water.
4	Plug the unit into a grounded outlet.
5	For maximum efficiency, refer to 7.1 Optimizing Your Ultrasonic Bath, before proceeding.

NOTICE	
1	If this is the first time you are running the unit, or if you have changed cleaning solution, you must degas the solution. If not, skip to 6.3.3 Cleaning Items (Treating Samples)."

6.3.1 MH Series Explanation of Controls

Figure 6.2 MH Series Controls




Table 6.6 MH Series Explanation of Controls

Control	Function
	This switch is located on the back of the unit, next to the power cord receptacle.
Main Power	Press the on side to power on the unit
Switch	Press the off side to power off the unit
	When operating the unit, normally leave the Main Power switch in the (on) position, and use the Timer Knob to activate ultrasonics.
	Activates heat to 60° C (140° F) maximum.
Heat Switch	Refer to <u>4.3 Temperature</u> for further information on temperature.
	Activates ultrasonics and sets time.
Timer Knob	Turn clockwise for timed operation (0–60 minutes)
TITLET KITOD	Turn counterclockwise to the HOLD position for continuous operation
	Turn to the zero position to turn unit Off.

6.3.2 Degassing

 Table 6.7
 For initial cleaning solution degassing.

Step	Action
1	Turn Main Power switch on.
2	Turn Heat switch on.
3	Turn the Timer Knob clockwise to 5–10 and let the unit run to allow the solution to "degas". NOTICE Refer to 6.5.11 Solution for information on degassing.



6.3.3 Cleaning Items (Treating Samples)

NOTICE	
i	To stop ultrasonics at any time, turn the Timer Knob to the zero position.

Table 6.8Treating Samples

Step	Action
1	Turn Main Power switch on.
2	Turn the Timer Knob clockwise to set the amount of time (0–60 minutes) you wish the items to be cleaned. Turn the Timer Knob counterclockwise to the HOLD position for continuous operation.
3	Place the items into a basket, perforated tray, or beakers in a positioning cover.
4	If using beakers or a solid tray, add cleaning solution to beakers or tray to cover the items.
5	Slowly lower the tray or beakers into the tank. Do not allow items to contact the tank bottom.
6	When items are clean, slowly remove them from the tank.
7	Rinse the clean items with clean water and dry them, if necessary.

6.4 CPX Series

CAUTION	General Warning
\wedge	 Do not place parts or containers directly on the bottom of the tanks; use a tray or wire to suspend items. Direct placement can cause the units to fail Do not allow the solution to drop more than 3/8 inch (1 cm) below the operating level line with ultrasonics on
	Do not ever use alcohol, gasoline or flammable solutions. Doing so could cause a fire or explosion. Use only water-based solutions
	Do not ever use mineral acids. These could damage the tank
	Failure to comply with these cautions will void your warranty.

Table 6.9Before you begin

Step	Action
1	Select your cleaning solution (refer to <u>4.5 Solution Effect on Metals</u>).
2	Allowing for the volume of the parts you will be cleaning and leaving room for cleaning solution, fill the tank with warm tap water to the operating level line.
3	Add cleaning solution to the tank water.
4	Plug the unit into a grounded outlet.
5	For maximum efficiency, refer to 7.1 Optimizing Your Ultrasonic Bath, before proceeding.

NOTICE	
1	If this is the first time you are running the unit, or if you have changed cleaning solution, you must degas the solution. If not, skip to <u>6.4.4 Cleaning Items (Treating Samples)</u> ."

6.4.1 CPX Explanation of Controls

Figure 6.3 CPX Series Controls



Table 6.10 CPX Series explanation of controls

Control	Function
	This switch is located on the back of the unit, next to the power cord receptacle.
Main Power	Press the on side to power on the unit
Switch	Press the off side to power off the unit
	When operating the unit, normally leave the Main Power switch in the on position, and use the On/Standby key to switch between the operating state and standby state.
し し	On/Standby When the Main Power switch on the rear panel is in the on position, press to power on/off the unit.
	Up/Down Keys
$oxed{\triangle}$	Press to increase/decrease ultrasonic or degassing cycle time (hold for quick increments/decrements).
	Time values are circular, pressing Up from 99 minutes takes you to Constant Sonics Mode (Constant Sonics icon and "" display on the LCD) and then to 1 minutes. Pressing Down from 1 minutes takes you to Constant Sonics Mode and then to 99 minutes.
	During power-up, use to select high or low ultrasonic power output.

Table 6.10 CPX Series explanation of controls

Control	Function
	Sonics
	Press to activate ultrasonics. If running in Timed Mode, a timer will begin to count down and ultrasonics will stop at 0 minutes. In Constant Sonics Mode (Constant sonics icon and "" on the display), timer has no function.
SONIC	Press sonics key again to deactivate ultrasonics.
	If running in Timed Mode, press Up and Down keys to adjust the ultrasonic cycle time (adjustable from 1 to 99 minutes).
	Degas
DEGAS	Press to degas the solution or to run a degas application. A default timer of 5 minutes will begin to count down and degassing will stop at 0 minutes.
	Press Degas key again to stop degassing the solution.
	During a degas cycle, press Up and Down keys to adjust the degas cycle time (adjustable from 1 to 99 minutes).
	Refer to 6.5.11 Solution for information on degassing.

6.4.2 CPX Series LCD Description

 Table 6.11
 CPX Series LCD description.

Reference	Function
	Power Level
	Displayed for 15 s only during power-up, shows the current ultrasonic output power selection.
	Press the Sonics or Degas key to go into normal operating mode.
	Press Up or Down keys to change between high (HI) and low (LO) power ultrasonics.
	Sonics/Degas Timer
	Displays the duration of a timed ultrasonic or degas cycle.
	Press Up and Down keys to adjust ultrasonic or degassing cycle time (adjustable from 1 to 99 minutes).
	In Constant Sonics Mode, "" is displayed.
	Constant Sonics
	Indicates the unit is operating in Constant Sonics Mode.
	In Constant Sonics Mode, sonics will remain on until the Sonics key is pressed or the unit is turned off.

 Table 6.11
 CPX Series LCD description.

Reference	Function
	Sonics On
	Indicates sonics are active.
	If running in Timed Mode, ultrasonics will remain on until the timer reaches 0 minutes.
	In Constant Sonics Mode, ultrasonics will remain on until the Sonics key is pressed or the unit is turned off.
	Degas On
	Indicates the unit is in Degas Mode.
0 0 ₀ 0 0 0	In Degas Mode, degassing will continue until the timer reaches 0 minutes.
	Refer to 6.5.11 Solution for information on degassing.
	Alarm
	Alarm Bell icon flashes when the unit encounters an abnormal operating condition.
	Refer to 7.2 Troubleshooting for information on troubleshooting.

6.4.3 Degassing

For initial cleaning solution degassing.

NOTICE	
1	To stop degassing at any time, press the Degas key.

Table 6.12 Degassing your CPX Series unit

Step	Action
1	Turn Main Power switch on.
2	Press the On/Standby key to turn on the unit.
3	Press Degas key once to start the degas process. Default degas time is 5 minutes. If necessary, use Up/Down keys to alter degas time during a degas cycle. NOTICE Refer to 6.5.11 Solution for information on degassing.

Table 6.12 Degassing your CPX Series unit

Step	Action
4	After completing the degas time, you are ready to set operating parameters.

6.4.4 Cleaning Items (Treating Samples)

NOTICE	
1	To stop ultrasonics at any time, press the Sonics key.

 Table 6.13
 Treating Samples

Step	Action
1	Turn Main Power switch on.
2	Press the On/Standby key to turn on the unit.
	Set the amount of time you wish the items to be cleaned, or select Constant Sonics Mode:
3	Use Up/Down keys to increase/decrease cycle time (hold for quick increments/decrements)
	 Pressing Up key from 99 minutes or Down key from 1 minutes takes you to Constant Sonics Mode (Constant Sonics icon and "" display on the LCD screen)
4	Press the Sonics key to activate ultrasonics.
5	Place the items into a basket, perforated tray, or beakers in a positioning cover.
6	If using beakers or a solid tray, add cleaning solutions to beakers or tray to cover the items.
7	Slowly lower the tray or beakers into the tank. Do not allow items to contact the tank bottom.
8	When items are clean, slowly remove them from the tank.
9	Rinse clean items with clean, warm water and dry, if necessary.

6.5 CPXH Series

CAUTION	General Warning
	Do not place parts or containers directly on the bottom of the tanks; use a tray or wire to suspend items. Direct placement can cause the units to fail
	Do not allow the solution to drop more than 3/8 inch (1 cm) below the operating level line with heat or ultrasonics on
	Do not ever use alcohol, gasoline or flammable solutions. Doing so could cause a fire or explosion. Use only water-based solutions
	Do not ever use mineral acids. These could damage the tank
	Failure to comply with these cautions will void your warranty.

Table 6.14 Before you begin.

Step	Action
1	Select your cleaning solution (refer to 4.5 Solution Effect on Metals).
2	Allowing for the volume of the parts you will be cleaning and leaving room for cleaning solution, fill the tank with warm tap water to the operating level line.
3	Add cleaning solution to the tank water.
4	Plug the unit into a grounded outlet.
5	For maximum efficiency, refer to 7.1 Optimizing Your Ultrasonic Bath", before proceeding.

NOTICE	
1	If this is the first time you are running the unit, or if you have changed cleaning solution, you must degas the solution. If not, skip to 6.5.5 Cleaning Items (Treating Samples) in Timed Sonics Mode."

6.5.1 CPXH Series Explanation of Controls

Figure 6.4 CPXH Series Controls



 Table 6.15
 CPXH Series explanation of controls.

Control	Function
Main Power Switch	 This switch is located on the back of the unit, next to the power cord receptacle. Press the on side to power on the unit Press the off side to power off the unit. When operating the unit, normally leave the Main Power switch in the on position, and use the On/Standby key to switch between the operating state and standby state
(山)	On/Standby When the Main Power switch on the rear panel is in the on position, press to power on/off the unit.
	Up/Down Keys
$oxed{\Delta}$	Press to increase/decrease ultrasonic or degassing cycle time (hold for quick increments/decrements).
	Time values are circular, pressing Up key from 99 minutes takes you to 1 minutes. Pressing Down key from 1 minutes takes you to 99 minutes.
	If the Fn key was pressed, use the Up/Down keys to adjust function settings.
HEAT	Heat Press to turn heater on/off. Heater will shut off when set temperature is attained.

 Table 6.15
 CPXH Series explanation of controls.

Control	Function
	Sonics
	Press to activate ultrasonics. If running in Timed Mode, a timer will begin to count down and ultrasonics will stop at 0 minutes. In Constant Sonics Mode (Constant Sonics icon and "" on the display), timer has no function.
SONIC	Press Sonics key again to deactivate ultrasonics.
SUNIC	If running in Timed Mode, press Up and Down keys to adjust the ultrasonic cycle time (adjustable from 1 to 99 minutes).
	Degas
DEGAS	Press to degas the solution or to run a degas application. The degas timer will begin to count down from its current setting and degassing will stop at 0 minutes.
	Press Degas key again to stop degassing the solution.
	During a degas cycle, press Up and Down keys to adjust degas time (adjustable from 1 to 99 minutes).
	Refer to 6.5.11 Solution for information on degassing.
	Auto
AUTO	Press to begin an auto cycle. In Auto Mode, the following actions are carried out automatically by the controller:
	Heater is turned on to bring bath to set temperature
	 When set temperature is reached, ultrasonics are activated. The unit will abort the auto cycle and flash the AUTO icon if set temperature is not reached within a 120-minute period
	When ultrasonics timer reaches 0 minutes, the auto cycle is finished
	If at any point during an auto cycle the degas key is pressed, a degas cycle will begin. If ultrasonics has already started, the ultrasonics timer will restart after the degas period.

 Table 6.15
 CPXH Series explanation of controls.

1 able 6.15	CPXH Series explanation of controls.
Control	Function
	Press the Fn key to access less-frequently used function. Press 1x to Set Target Temp Press 2x to Set Constant Sonics Press 3x to Set Power Level Press 4x Sel. Temp Units Press 5x to Set Degas Time Press 6x Ready State (Set Sonics Time) The appropriate icon will flash to indicate which option is selected.
	If no key is pressed after 15 seconds the unit will save any changes and return to the Ready state.
	Press the Fn key again after making any changes to scroll through the rest of the options and return to the Ready state.
	The following options are available:
	Set Temperature (Fn 1x): Press Up and Down keys to increase/decrease the bath set temperature
	Fn (1x) (Indicates) (Blinking)
Fn	Auto min
	Timed/Constant Sonics (Fn 2x): Press Up key to select Constant Sonics Mode (Constant Sonics icon and "" on the display) Press down key to select Timed Sonics Mode
	Fn (2x) (Indicates) Blinking

Table 6.15 CPXH Series explanation of controls.

Control **Function** Full/Low Power (Fn 3x): Press up key to select full power ultrasonic output. Press down key to select low power ultrasonic output (3x)Indicates hn Blinking ∞ Temperature Units (Fn 4x): Press key to select Fahrenheit (°F). Press Down key to select Celsius (°C) (4x)**Indicates** Blinking Degas Time (Fn 5x): Press Up/Down keys to increase/decrease degas time (hold for quick increments/decrements). Time values are circular, pressing Up from 99 minutes takes you to 1 minute. Pressing Down from 1 minute takes you to 99 minutes (5x)**Indicates** Blinking

6.5.2 CPXH Series LCD Description

 Table 6.16
 LCD Description for CPXH Series.

Item	Function
(L)	 Sonics/Degas Set Time Displays the set time for a timed ultrasonic or degas cycle. Press Up and Down keys to adjust ultrasonic or degassing cycle time (adjustable from 1 to 99 minutes). In Constant Sonics Mode, "" is displayed
→	Set Temperature Displays the target temperature. Temperature units are indicated by the °F (for Fahrenheit) or °C (for Celsius) right of the Current Temperature icon.
o°F °C	Current Temperature Displays the current tank temperature as measured by the unit. Temperature units are indicated right of the icon as either °F (For Fahrenheit) or °C (for Celsius). Units can be switched using the Fn key. See Fn key description on Table 6.15.
(L)	Sonics/Degas Timer Displays the remaining time of a running timed ultrasonic or degas cycle. Press up and down keys to adjust ultrasonic or degassing cycle time (adjustable from 1 to 99 minutes).
AUTO	 Auto Indicates the unit is in Auto Mode. In Auto Mode, the following actions are carried out automatically by the controller: Heater is turned on to bring bath to set temperature When set temperature is reached, ultrasonics are activated. The unit will abort the auto cycle and flash the icon if set temperature is not reached within a 120-minute period When ultrasonics timer reaches 0 minutes, the auto cycle is finished If at any point during an auto cycle the degas key is pressed, a degas cycle will begin. If ultrasonics has already started, the ultrasonics timer will restart after the degas period.
000	Constant Sonics Indicates the unit is operating in Constant Sonics Mode. In Constant Sonics Mode, ultrasonics will remain on until the Sonics key is pressed or the unit is turned off.

 Table 6.16
 LCD Description for CPXH Series.

Item	Function
##	Heat Indicates the heater is on. Heater will shut off when set temperature is attained.
	Sonics On
	Indicates sonics are active.
	If running in Timed Mode, ultrasonics will remain on until the timer reaches 0 minutes.
	In Constant Sonics Mode, ultrasonics will remain on until the Sonics key is pressed or the unit is turned off.
	Degas On
	Indicates the unit is in Degas Mode.
0 0 ₀ 0 0 0	In Degas Mode, degassing will continue until the timer reaches 0 minutes.
	Refer to <u>6.5.11 Solution</u> for information on degassing.
	Power Level
	Indicates the ultrasonic power output selection:
	Four bars indicate high power ultrasonics
= •	Two bars indicate low power ultrasonics
	Alarm
	Alarm Bell icon flashes when the unit encounters an abnormal operating condition.
	Refer to 7.2 Troubleshooting for information on troubleshooting.

6.5.3 Degassing

For initial cleaning solution degassing.

NOTICE	
1	To stop degassing at any time, press the Degas key.

Table 6.17 Degassing

Step	Action
1	Turn Main Power switch on.
2	Press the On/Standby key to turn on the unit.
	Default degas time is 5 minutes.
3	To change the degas time, press the Fn key until the Degas icon appears and the Set Time icon flashes. Then press the Up/Down keys to change the degas time.
	Press Degas key once to start the degas process.
4	If necessary, use up/down keys to alter degas time during a degas cycle.
	Refer to 6.5.11 Solution for information on degassing.
5	After completing the degas time, you are ready to set operating parameters.

6.5.4 Ultrasonics Operating Modes

Table 6.18 Ultrasonic Operating Modes

Mode	Action
Timed Sonics	In Timed Sonics Mode, a timer will begin to count down and ultrasonics will remain on until the timer reaches 0 minutes.
	For instructions, see <u>6.5.5 Cleaning Items (Treating Samples) in Timed Sonics Mode</u> .
Constant Sonics	In Constant Sonics Mode ultrasonics will remain on until the Sonics key is pressed or power is turned off to the unit.
	For instructions, see <u>6.5.6 Cleaning Items (Treating Samples) in Constant Sonics Mode</u> .
Auto	In Auto mode ultrasonics will start once set temperature is attained. Ultrasonics will remain on until the timer reaches 0 minutes.
	For instructions, see <u>6.5.7 Cleaning Items</u> (<u>Treating Samples</u>) in Auto <u>Mode</u> .

6.5.5 Cleaning Items (Treating Samples) in Timed Sonics Mode

NOTICE	
1	To stop ultrasonics at any time, press the Sonics key.

Table 6.19 Treating samples in Timed Sonics Mode

Step	Action
1	Turn Main Power on.
2	Press the On/Standby key to turn on the unit.
3	If necessary, degas the liquid. See <u>6.5.3 Degassing</u> for instructions.
	Set the amount of time you wish the items to be cleaned:
	Use up/down keys to increase/decrease cycle time (hold for quick increments/decrements).
	Set the tank temperature:
	Press the Fn key until the Set Temperature icon flashes
5	 Press the Up/Down keys to alter the setting to the tank temperature you wish to reach
5	Press the Heat key once to activate heat. The Heat icon appears
	Units can be switched between °F or °C using the Fn key. See Fn key description on <u>6.5.1 CPXH Series Explanation of Controls</u> .
	Set the ultrasonic power level:
6	Press the Fn key until the Power Level icon flashes
	 Press the Up key to select high power ultrasonics or press the Down key to select low power ultrasonics
7	Press the Sonics key to activate ultrasonics.
N I	Place the items into a basket, perforated tray, or beakers in a positioning cover.
9	If using beakers or a solid tray, add cleaning solution to beakers or tray to cover the items.
	Slowly lower the tray or beakers into the tank. Do not allow items to contact the tank bottom.
11	When items are clean, slowly remove them from the tank.
12	Rinse clean items with clean, warm water and dry, if necessary.

6.5.6 Cleaning Items (Treating Samples) in Constant Sonics Mode

NOTICE	
1	To stop ultrasonics at any time, press the Sonics key.

Table 6.20 Treating Samples in Constant Sonics Mode

Step	Action
1	Turn Main Power switch on.
2	Press the On/Standby key to turn on the unit.
3	If necessary, degas the liquid. See <u>6.5.3 Degassing</u> for instructions.
4	Change sonics mode: • Press the Fn key until the Constant Sonics icon and the Set Time icon flash • Press the Up key to select Constant Sonics Mode
5	 Set the tank temperature: Press the Fn key until the Set Temperature icon flashes Press the Up/Down keys to alter the setting to the tank temperature you wish to reach Press the Heat key once to activate heat. The Heat icon appears NOTICE Units can be switched between °F or °C using the Fn key. See Fn key description on Table 6.15 .
6	Set the ultrasonic power level: • Press the Fn key until the Power Level icon flashes • Press the Up key to select high power ultrasonics or press the Down key to select low power ultrasonics
7	Press the Sonics key to activate ultrasonics.
8	Place the items into a basket, perforated tray, or beakers in a positioning cover.
9	If using beakers or a solid tray, add cleaning solution to beakers or tray to cover the items.
10	Slowly lower the tray or beakers into the tank. Do not allow items to contact the tank bottom.
11	When items are clean, slowly remove them from the tank.
12	Rinse clean items with clean, warm water and dry, if necessary.

6.5.7 Cleaning Items (Treating Samples) in Auto Mode

NOTICE	
1	To stop ultrasonics at any time, press the Sonics key.

 Table 6.21
 Treating Samples in Auto Mode

Step	Action
1	Turn Main Power switch on.
2	Press the On/Standby key to turn on the unit.
3	If necessary, degas the liquid. See <u>6.5.3 Degassing</u> for instructions.
	Set the amount of time you wish the items to be cleaned:
4	Use Up/Down keys to increase/decrease cycle time (hold for quick increments/decrements)
	Set the tank temperature:
	Press the Fn key until the Set Temperature icon flashes
5	Press the Up/Down keys to alter the setting to the tank temperature you wish to reach
	Press the Heat key once to activate heat. The Heat icon appears
	Units can be switched between °F or °C using the Fn key. See Fn key description on 6.5.1 CPXH Series Explanation of Controls
	Set the ultrasonic power level:
6	Press the Fn key until the Power Level icon flashes
	Press the Up key to select high power ultrasonics or press the Down key to select low power ultrasonics
7	Press the Auto key to begin Auto Cycle. Heater will turn on and sonics will start once set temperature is attained.
8	Place the items into a basket, perforated tray, or beakers in a positioning cover.
9	If using beakers or a solid tray, add cleaning solution to beakers or tray to cover the items.
10	Slowly lower the tray or beakers into the tank. Do not allow items to contact the tank bottom.
11	When items are clean, slowly remove them from the tank.
12	Rinse clean items with clean, warm water and dry, if necessary.

6.5.8 CPXH Temperature Calibration

The CPXH unit temperature measurement is factory calibrated. Use the following instructions to perform periodic calibrations:

Table 6.22 CPXH temperature calibration

Step	Action
1	The ultrasonic bath liquid may be at room temperature or may be heated-up to a desired operating temperature (e.g. 40° C).
2	Press the Fn key 4 times until the Current Temperature icon starts blinking. Press the Up key to select °F. Press the Fn key 2 more times to return to the Ready State.
3	Press the On/Standby key to turn off the unit.
4	Simultaneously, press both the On/Standby and the Fn key. Only the bottom left digits and the Current Temperature icon should turn on.
5	Stir the solution for 15 seconds to ensure thermal uniformity.
6	Wait 2 minutes after turning the unit on before taking measurements. This allows for the display to be properly updated.
7	Use the Up/Down keys to change the display temperature to match the actual tank temperature.
8	Press the On/Standby key to end calibration.

6.5.9 Draining Your Unit

WARNING	General Warning
<u>^</u>	Do not immerse the unit in water. Unplug the unit from the power source.

Models 1800 and 2800 do not have a drain. To empty, use the indented side of the rim to pour the used solution into a waste disposal unit, rinse the tank thoroughly and refill with new solution.

Figure 6.5 Draining of Units 1800 and 2800



Models 3800, 5800, and 8800 include a drain and valve kit.

Table 6.23 Draining your ultrasonic bath

Step	Action
1	Place the unit to allow easy reach of the drain tube into a waste disposal unit.
2	Remove the thread protecting cap from the end of the unit's drain pipe. This will expose the white teflon sealing tape on the drain pipe's threads.

 Table 6.23
 Draining your ultrasonic bath

Step **Action** Hand tighten the drain valve onto the drain pipe over the white teflon sealing tape. Finish tightening the valve in place using an adjustable or a 21mm wrench. Tighten the valve no more than one full turn when using the wrench until the handle is on top. 3 CAUTION Over tightening of the valve can cause damage to the ultrasonic tank. Always use teflon sealing tape or a sealing paste designed for use with stainless steel if retightening or refitting of the drain valve is required. Hand tighten the hose adaptor into the end of the drain valve. Slide the drain tube over the barbed hose adaptor end. 4 Close the drain valve by turning the handle perpendicular to the valve body 5 and the unit is ready to fill with solution. To open the valve and drain the tank, turn the handle so that it is in line with the valve body.

6.5.10 Solution Temperature Measurement

The following instructions provide an accurate method to obtain consistent thermal measurements using a calibrated temperature measurement instrument. These readings can be used for cleaning process control or to verify the accuracy of the CPXH temperature readings.

Table 6.24 Measuring the Solution Temperature

Step	Action
1	Ensure that sonics and heaters are off.
2	Stir the solutions for 15 seconds to ensure thermal uniformity.
3	For CPXH models, wait 2 minutes after turning the unit on before taking measurements. This allows for the display to be properly updated.
4	Suspend a thermocouple in the bath without allowing the probe to touch the tank walls.

6.5.11 Solution

Table 6.25 Solution Usage


Item	Definition
Solution Activity	The amount of visible activity is not necessarily related to optimum cavitation for cleaning.
Degassing 1	Fresh solutions contain many dissolved gases (usually air), which reduce effective ultrasonic action. Although solutions will naturally degas over time, using Degas Mode speeds up the degassing process. Solutions that have been sitting unused for 24 hours or longer have reabsorbed some gases.
Degassing 2	Degassing mode is also used where gas has to be removed from liquids or samples.
Heat	Increases the chemical activity of cleaning solutions.
Solvents	Never use solvents. Vapors of flammable solutions will collect under the unit, where ignition is possible from electrical components.
Surface Tension	It can be reduced by adding solution to the bath. Reduced surface tension will increase cavitation intensity and enhance cleaning.
Renewal	Replace cleaning solutions often to increase ultrasonic cleaning activity. Solutions, as with most chemicals, will become depleted over time. Solutions can become contaminated with suspended soil particles which coat the tank bottom, inhibiting ultrasonic activity.


6.6 Cleaning Methods

There are two methods of cleaning - direct and indirect. Each has advantages and disadvantages. When in doubt, run test samples using both methods to decide which one produces the best results for you.

6.6.1 Direct Cleaning Method

Figure 6.6 Direct Cleaning Method





How it works:


- Fill the tank with warm water and a cleaning solution
- Place the items to be cleaned in a perforated tray and lower them into the tank. You can also suspend items on a wire and then immerse them in the solution


The advantages of this method are:

- · The simplicity of operation
- Cleaning effectiveness

6.6.2 Indirect Cleaning Method

Figure 6.7 Indirect Cleaning Method





How it works:

- Fill the tank with warm water and a cleaning solution. The tank can be filled with any amount of diluted solution as long as it reaches the water level line once the items to be cleaned and accessories are placed into the tank
- · Pour your solution medium into one or more beakers or into a solid insert tray
- Place the beakers in a beaker positioning cover or a solid insert tray to fit your unit. Beakers should not touch the tank's bottom


The advantages of this method are:


- · Removed soil stays in the beaker or tray so you can easily examine, filter or discard it
- You can use one or more solutions at the same time (two completely different cleaning solutions or one beaker or tray with a cleaning solution and one with a rinse solution)
- · Cleaning solution in your tank needs to be changed less often

6.6.3 Non-Cleaning Application

This method can be used for sample preparation, which includes degassing liquids, mixing, homogenization, dissolving solids, cell lysing and dispersion or particles.

Figure 6.8 Non Cleaning Application





How it works:

- Fill the tank with water and wetting agent. The tray or beakers can be filled with any amount of solution as long as the water in the tank outside the tray or beakers reaches the water level line
- Place the beakers in a beaker positioning cover, an insert tray or an insert basket to fit your unit, or place the beakers and flasks onto a Branson support rack. Beakers should not touch the tank's bottom



Chapter 7: Maintenance

7.1	Optimizing Your Ultrasonic Bath64
7.2	Troubleshooting
7.3	Glass Slide Test
7.4	Service Centers
7.5	Information for Users on Disposal of Equipment

7.1 Optimizing Your Ultrasonic Bath

Follow these recommendations to optimize your Ultrasonic Bath unit.

Table 7.1 Tanks

Item	Maintenance
Cleaning	Check the tank for contamination whenever you change solution. If necessary, remove contaminants with a nonabrasive cloth and water.
Emptying	Always unplug the unit before emptying the tank. Empty the solution into a waste disposal unit.
Filling	Always unplug the line cord before filling the tank. Fill the tank to the operating level (with beaker/tray in place), using warm tap water.
Low Solution Level	Will cause the unit to fail. When you remove heavy or bulky loads from the tank, the solution level may drop below the operating level. If so, be sure to replace lost solution and degas, if necessary, depending on the amount used.
Overload	Do not rest any items on the tank bottom. Weight on the tank bottom dampens sound energy and will cause damage to the transducer. Instead, use a tray and/or beaker positioning cover to support all items. Allow at least 1 inch (2.5 cm) between the tank bottom and the beaker or receptacle for adequate cavitation.
Covers	Allow the unit to heat up faster, to a higher temperature, and avoid excessive liquid evaporation. However, obstructing the cover vents will cause the unit to overheat.

7.2 Troubleshooting

If your unit does not operate satisfactorily, please check the tables below for possible causes before calling your authorized service center.

WARNING	General Warning
	High voltage inside - dangerous shock hazard. DO NOT attempt to disassemble or repair the unit.

Table 7.2 Troubleshooting

Problem	Cause	What to do	
Unit will not start	Unit not plugged in properly.	Plug into functioning electrical outlet.	
	M/MH - Mechanical timer not ON.	Turn timer clockwise. Press power switch ON.	
	CPX/CPXH - POWER switch not ON.	Call nearest authorized service center.	
	CPX/CPXH - On/Standby key malfunctioning. Blown fuse.	Call nearest authorized service center.	
Unit operates but does not heat solution	Heater malfunctions.	Call nearest authorized service center.	
	MH - HEAT not ON.	Turn heat ON. See "Operating your Unit" on page 33.	
	CPXH - HEAT not set properly.		
	CPXH - membrane malfunctioning.	Call nearest authorized service center.	
Clogged drain	Clogged drain.	Call nearest authorized service center.	
GFI protected outlet trips	Units may cause GFI circuit trips.	Connect unit to an unprotected outlet.	
Unit operates, but does not reach set temperature	Malfunctioning heater or sensor components.	Call nearest authorized service center.	

Table 7.2Troubleshooting

Problem	Cause	What to do
Err on actual temp and alarm Icon is on. Sonics and Degas operate. Auto and Heat are inactive.	Malfunctioning sensor components.	Call nearest authorized service center.
Unit operates but display does not function.	CPX/CPXH - Control board malfunctioning.	Call nearest authorized service center.
Unit stops operating and display is blank with only alarm icon on.	Overheat condition.	For CPXH units, if temperature of 75° C is reached, ultrasonics will stop and won't resume until temperature falls back to 69° C. Check solution level. Refer to 4.3 Temperature for information on over temperature protection.
	Solution is not degassed.	Make sure that tank was filled with warm tap water plus cleaning solution and has run 5-10 minutes.
Decreased ultrasonic	Solution is spent Solution level is incorrect for load.	Change solution.
notice Refer to 7.3 Glass Slide Test for cavitation check.		Adjust solution to within 3/8 inch (1 cm) of the tank's operating level line with load.
	Tank bottom is covered with soil particles.	Empty, then clean tank with warm water. Wipe with a nonabrasive cloth.
	Using deionized water in the tank.	Deionized water does not cavitate as actively as soapy tap water.

7.3 Glass Slide Test


Check your ultrasonic bath periodically to test the level of activity of the ultrasonic cavitation. Frequency of testing will depend on your use of the unit, however, Branson suggests running this test monthly.

You will need the following equipment:

- Frosted microscope glass slide (1" x 3"), such as Fisherbrand®¹ #12-550-343 frosted microscope slides, or equivalent;
- · No. 2 lead pencil; and
- General purpose household cleaning solution, such as Dawn®² liquid soap

Test procedure:

- 1. Prepare a fresh solution with general purpose household cleaning solution (concentration 1%) and warm tap water 49° C -60° C $(120^{\circ}$ F -140° F).
- 2. Fill the tank to within 3/8 inch (1 cm) of the "operating level" line.
- 3. Turn the ultrasonics on for at least five to ten minutes to allow for degassing.
- 4. Prepare the glass slide by first wetting the frosted portion with tap water.



- 5. With the No. 2 pencil, on the frosted portion make an "X" from corner to corner.
- 6. Immerse the frosted end of the slide into the solution. Hold the slide vertically and center it in the solution.
- 7. Make sure that model CPX/CPHX models are in Timed or Constant Sonics Mode, not Degas Mode, then turn ultrasonics On.

The ultrasonics will begin immediately to remove the lead from the slide. All lead should be removed within 10 seconds. If your unit passes this test, its ultrasonic cavitation is acceptable.

NOTICE	
1	To ensure consistency from test to test, be sure to repeat test conditions—use the same solution concentration, liquid level, temperature, type of pencil, length of degassing, etc.

- 1. Fisherbrand is a registered trademark of Fisher Scientific Company.
- 2. Dawn is a registered trademark of Procter & Gamble Company U.S.A.

7.4 Service Centers

With normal use, your Ultrasonic Bath should not require servicing. However, if it fails to operate satisfactorily, first try to diagnose the problem by following the suggestions in the Troubleshooting Guide on <u>7.2 Troubleshooting</u>.

WARNING	General Warning
	You will void the warranty if you disassemble your unit. High voltage inside the unit is dangerous.

If you find that your unit needs repair, carefully pack and return it to your local distributor. If under warranty, remember to include proof of purchase. Your unit will be shipped by ground service unless you specify otherwise.

 Table 7.3
 Authorized Service Centers (North America)

Name	Address	Tel/Fax Number
Alpha Omega Electronics Corp.	2821 National Drive Garland, Tx 75041	Tel: 972-271-5571 Tel: 800-540-4967 Fax: 972-840-3668
Crystal Electronics Inc.	1251 Gorham St. Unit 2 Newmarket, ON Canada L3Y 8Y6	Tel: 905-953-9129 Fax: 905-953-7965
Paragon Electronics	6861 SW 196th Ave. Suite 404 Pembroke Pines, Florida 33332	Tel: 954-434-8191 Fax: 954-434-8385
Master Sonics Repair Center	77 Whiting St. Plainville, CT 06062	Tel: 860-410-1700 Tel. 800-737-2198 Fax: 860-410-1704

Table 7.4 Technical Support (North America)

Name	Address	Tel/Fax Number
Branson Ultrasonics Corp.	41 Eagle Road P. O. Box 1961 Danbury, CT 06813-1961	Tel: 203-796-0339 Tel: 203-796-2296 Tel: 800-732-9262 Fax: 203-796-2240

7.5 Information for Users on Disposal of Equipment



This symbol indicates separate collection of waste electrical and electronic equipment in the EU-countries and EEA (European Economic Area).

Please do not dispose the product with the general household waste. Please use the return and collection system in your country for the disposal of this product.

Index

```
Α
 accessories 10
 alkaline 22
 alteration 5
 assistance 2
C
 caustic 22
 cavitation 8
 chemicals 23
 cleaning 64
 covers 64
D
 degas 32
 direct cleaning 59
 disposal 71
 dissolved gases 58
 dissolving 8
Ε
 emptying 64
F
 FCC regulations 14
 filling 64
 flammable solutions 34
G
 ground leakage current 14
Н
 harmful chemicals 23
 IET 4
 implode 8
 implosions 8
 indirect cleaning 60
L
 load size 6
 low solution level 64
M
 mineral acids 34
```

```
molded dip 9
 MOVs 4
Ν
 non-cleaning application 61
0
 overheat 64
 overload 64
 overvoltages 4
Ρ
 personal injury 3
 probe 57
 property damage 3
R
 rinsing items 6
S
 safety 2
 solution level 6
Т
 temperature 21
 test conditions 67
 thermal measurements 57
 thermal uniformity 57
 transducers 9
U
 ultrasonic sound 8
V
 vents 3
W
 warranty 68
```

water-based solutions 34